

[illegible]

1. Pre-cut exp. joint material shall be used in all exp. joints.
2. Dummy joints shall be installed at 10 ft. intervals, maximum.
3. Exp. joints shall be installed at 40 ft., maximum.
4. Exp. joints shall be located at ends of radius.
5. Exp. joints shall be located a minimum of 5 ft. from inlet structure.

# DESIGN STANDARD FOR VALLEY GUTTER

<i>W. E. Gandy</i>	<i>5-7-81</i>
<i>W. E. Gandy</i>	<i>5-7-81</i>
DEPUTY DIRECTOR/CIVIL ENGINEER	DATE

DWG. NO. 3